

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1203


Dated: 03/06/2025

It is certified that an inspection team headed by RAVI PRAKASH (EXECUTIVE ENGINEER) PHED BHABUA
 (Name of Officers with designation) from PHED (BHABUA)

(Name of Department/ Office) inspected the DAV School, Jaddupur, Saitha, Bhabua, Kaimur, Bihar

(Name & Address of the school) on (date of inspection) and found that the DAV School, Jaddupur (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of ONE YEAR

Signature with Seal:  03.6.25

Name

RAVI PRAKASH

Designation


EXECUTIVE ENGINEERName & Address of the Office / Department : PHED (BHABUA)


To

DAV SCHOOL, JADDUPUR
SAITHA, BHABUA, KAIMUR, BIHAR

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.


 DIRECTOR
 DAV SCHOOL
 JADDUPUR SAITHA KAIMUR BIHAR


 Principal
 DAV SCHOOL
 SAITHA JADDUPUR KAIMUR BIHAR

Office of the Executive Engineer
Public Health Division, Kaimur (Bhabhua)
Division Laboratory -Bhabhua

Zone - Patna
Division Name - Bhabhua

Issue Date -17-06-2025

Water Sample Details						(Values in mg/L, Except pH otherwise mentioned)														
Sl. No.	Block	Panchayat / Town	Village / Locality	Name of Habitation / Ward No.	Location/ Source of sample	PH	Turb.	EC	TDS	T. Hard	Ca	Mg	Cl	T. Alka	Fe	NO3	SO4	F	Total calc.	
1	Bhabhua	Bhabhua	Jaddupur	D.A.V School Jaddupur	Submersible	7.10	0.25	636.00	412.00	280.00	68.00	31.20	30.00	300.00	0.20	BDL	10.00	0.35	(-VE)	
Desirable Limit						6.5-8.5	1.00	—	500	200	75	30	250	200	1	45	200	1		
Drinking Water Specification (Second revision) IS 10500 / 2012 Permissible limit in absence of alternate source.						NR	5.0 NTU	—	2000	600	200	100	1000	600	NR	NR	400	1.5		

* Notes: Water Sampled on 10/01/2023

* Note :- Water Sample collected by - D.A.V School Jaddupur Staff

* BDL = Below Detection Limit

Ashok Kumar
 17/06/2025
 Chemist
 P.H. Division, Bhabhua

Sandeep
 17/6/25
 Assistant Engineer
 P.H.Division, Bhabhua

[Signature]
 17/6/25
 Executive Engineer
 P.H.Division, Bhabhua

[Signature]
 DIRECTOR
 DAV SCHOOL
 JADDUPUR SAITHA KAIMUR BHAR

[Signature]
 Principal
 DAV SCHOOL
 SAITHA JADDUPUR KAIMUR BHAR