

**Office of the Executive Engineer
Public Health Division, Kaimur (Bhabhua)
Division Laboratory - Bhabhua**

Zone - Patna
Division Name - Bhabhua

Issue Date - 17-06-2025

Water Sample Details					(Values in mg/L, Except pH otherwise mentioned)														
Sl. No.	Block	Panchayat / Town	Village / Locality	Name of Habitation / Ward No.	Location / Source of sample	PH	Turb.	EC	TDS	T. Hard	Ca	Mg	Cl	T. Alka	Fe	NO3	SO4	F	Total coli.
1	Bhabhua	Bhabhua	Jaddupur	D.A.V School Jaddupur	Submersible	7.10	0.25	636.00	412.00	280.00	68.00	31.20	30.00	300.00	0.20	BDL	10.00	0.35	(-VE)
Desirable Limit						6.5-8.5	1.00	-	500	200	75	30	250	200	1	45	200	1	
Drinking Water Specification (Second revision) IS 10500 / 2012 Permissible limit in absence of alternate source.						NR	5.0 NTU	-	2000	600	200	100	1000	600	NR	NR	400	1.5	

* Note :- Water Sample collected by - D.A.V School Jaddupur Staff

* BDL = Below Detection Limit

Apurk Kumar
Chemist
17/06/2025

Sanjay
17/6/25
Assistant Engineer
P.H. Division, Bhabhua

[Signature]
Executive Engineer
P.H. Division, Bhabhua
17/6/25