

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No 2033Dated 23/07/2026It is certified that an inspection team headed by RAVI PRAKASH(Name of Officers with designation) from E.E. PHED(Name of Department/Office) inspected the DAV School, Saitha, Jaddupur, Bhabua, Kaimur, Bihar

(Name & Address of the school) on (date of inspection) and found that the DAV School, Jaddupur (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Govt.

The above is valid for a period of One year.

Signature with Seal

Name

RAVI PRAKASH**Executive Engineer**
P.H. Division Bhabua

Designation

E.E.

Name & Address of the Office/Department

P.H. DIVISION
BHABUA, KAIMUR

To

DAV School,Saitha, Jaddupur

(Name & Address of the Institution)

The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf



Government of Bihar
Public Health Engineering Department
District Level Water Testing Laboratory - Public Health Division - Bhabua
Drinking Water Quality Test Monitoring Report

Report No. - 116/2026PP
 PPDPP

Zone - Patna

District - Kaimur (Bhabua)

Issue Date - 22-07-2026

Water Sample Details								Tested Parameter in mg/L (Except pH)													Remarks
Sl. No.	Block	Panchayat / Town	Village / Locality	Habitation / Ward No.	Source of sample	Sample received date	Final Tested date	pH	Turb	EC	TDS	T. Hard	Ca	Mg	T. Alka	Cl	NO 3	F	T. Coli		
1	BHABUA	DAV SCHOOL JADDUPUR BHABUA (KAIMUR)			Sumbersible	20-07-26	22-07-26	7.30	0.45	615.38	400.00	220.00	43.20	26.88	222.00	50.00	BDL	0.21	A		
Desirable Limit								6.5-8.5	1.0	—	500	200	75	30	200	250	45	1	* A = Absent / * P = Present		
Permissible limit in absence of alternate source (IS 10500-2012) 2nd revision								NR	5.0	—	2000	600	200	100	600	1000	NR	1.5			

Note :- All the parameter tested in this laboratory are found within the maximum permissible limit.

* Above given details of Water Sample collected and submitted in laboratory for water quality test. Sample Collected by School Staff.

Ashok Kumar
 22/07/2026
 Chemist / Asst. Chemist
 DLWT- Lab, P.H. Division,
 Kaimur (Bhabua)

Executive Engineer
 Public Health Division
 Kaimur (Bhabua)
Executive Engineer
 P.H. DIVISION BHABUA

* BDL = Below Detection Limit

* NT = Not Test

* A = Absent

* P = Present